



Evaluation Listing CCMC 13408-L

MASTERFORMAT: 07 21 19.02
Issued: 2009-01-07
Revised: 2009-04-14
Re-evaluation due: 2012-01-07

WALLTITE ECO

1. Evaluation

Conforms to CAN/ULC-S705.1-01 (including Amendments 1 and 2), “Thermal Insulation – Spray Applied Rigid Polyurethane Foam, Medium Density – Material Specification,” Type 1.

For retrofit construction, time before occupancy is one (1) day.

2. Description

A Type 1, spray-applied, rigid polyurethane foam of medium density. The foam system consists of two components: “Lupranate 17” isocyanate and a polyurethane resin identified as “Walltite Eco.”

The two components are mixed on site by a qualified installer with fixed-ratio positive displacement equipment.

The final cured product is purple in colour.

3. Standard and Regulatory Information

MORRISON HERSHFIELD has been identified by BASF Canada as the third-party organization that operates the field quality assurance program (FQAP) for “Walltite Eco” in accordance with CAN/ULC-S705.2-05, “Thermal Insulation – Spray Applied Rigid Polyurethane Foam, Medium Density – Application.”

See the Preface and the standard for explanation.

Listing Holder: BASF Canada Inc.
100 Milverton, 5th Floor
Mississauga, ON L5R 4H1
Tel: 289-360-1300
Fax: 289-360-6000

Plant(s): Toronto, ON

This Listing is issued by the Canadian Construction Materials Centre, a program of the Institute for Research in Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to <http://irc.nrc.gc.ca/ccmc>, or contact the Canadian Construction Materials Centre, Institute for Research in Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.